



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 10
WASHINGTON OPERATIONS OFFICE
300 Desmond Drive SE, Suite 102
Lacey, Washington 98503

September 30, 2008

FILE COPY

Mark Rozak
Soldotna Y Chevron
44024 Sterling Hwy
Soldotna, AK 99669-8029

Re: Underground Storage Tank (UST) Program Field Notice of Non-Compliance No. 1148
from the August 11, 2008, UST facility inspection of Soldotna Y Chevron, Soldotna,
Alaska (EPA ID No. AK518)

Dear Mr. Rozak:

The information that was received on September 30, 2008, satisfies the terms specified in Field Notice of Non-Compliance (FNNC) No. 1148, which was issued on August 11, 2008, for your facility. Therefore, EPA has granted final approval of this FNNC. Thank you for taking the necessary steps to bring your facility into compliance with the federal UST regulations.


To remain in compliance and to avoid being issued additional field notices of non-compliance or possible enforcement actions with monetary penalties, please remember to do the following:

- Continue to have your ATG conduct leak tests **monthly** and save the test reports.
- Conduct line tightness testing **annually** (Unleaded, Super-Unleaded and Diesel tanks)
- Continue to have the automatic line leak detectors tested **annually**.
- Continue with cathodic protection testing of the steel tanks and piping every 3 years.
- Maintain your pollution liability insurance.

Please review these reports and testing results to ensure that your equipment is functioning properly and that there is not a leak. You do not need to send in test results to us, but rather, they should be kept with your UST records and be available for review upon request.

If you have technical or regulatory questions in the future, please feel free to contact me at (360) 753-8072. EPA prefers to help people through compliance assistance, rather than having to use the enforcement process.

Sincerely,


Jim Greeves
EPA Settlement Lead